



Indiana State
Department of Health
An Equal Opportunity Employer

Mitchell E. Daniels, Jr.
Governor

Gregory N. Larkin, M.D., F.A.A.F.P.
State Health Commissioner

STATE OF INDIANA)
) SS: ADMINISTRATIVE ORDER OF THE INDIANA
COUNTY OF MARION) STATE DEPARTMENT OF HEALTH
Cause no. Gasoline Sample -Water in storage tank
Registration Number: H395234

IN THE MATTER OF THE OPERATION OF)
Clark)
735 Main Street)
Palmyra, Indiana 47164)

TO: Clark
735 Main Street
Palmyra, Indiana 47164

EMERGENCY STOP-SALE ORDER

You are **NOTIFIED** that the Division of Weights and Measures, Indiana State Department of Health, pursuant to Indiana Code 16-44-3-7 (2) and Indiana code 4-21.5-4 et seq. hereby **ORDERS YOU TO IMMEDIATELY STOP THE SALE** of motor fuel from the fuel pumps dispensing grades (87 Octane) motor fuel, at the facility known as **Clark**, located at **735 Main Street, Indiana 47164**.

This order is based upon the following: **Clark** is a motor fuel outlet facility engaged in the sale of motor fuel to the public.

On May 12, 2011 a Representative of the Division of Weights and Measures, Indiana State Department of Health, conducted an inspection of **Clark** facility of the Unleaded (87 Octane) grade of gasoline. The results of Sar-gel paste test conducted on said motor fuel storage tank reveals 3/4 inches of water in the unleaded 87 octane storage tank. On the same day 12 barrels of water was pump out of the 87 octane storage tank. This equals to 660 gallons of water from 87 octane storage tank.

This is a violation of the Indiana Code 16-44-3-1 et seq., and 410 IAC 12.1-2-2(a), "Standard Specification for Automotive Spark-Ignition Engine Fuel".

YOU ARE HEREBY ORDERED TO IMMEDIATELY STOP THE SALE of Unleaded (87 octane) Motor fuel from the fuel pumps dispensing at the facility known as: **Clark at 735 Main Street Palmyra, Indiana 47164**.



Indiana State
Department of Health
An Equal Opportunity Employer

Mitchell E. Daniels, Jr.
Governor

Gregory N. Larkin, M.D., F.A.A.F.P.
State Health Commissioner

This **ORDER** shall remain in effect until such time as the fuel has been upgraded in accordance with 410 IAC 12.1-2-3 (e) or has been disposed of in accordance with 410 IAC 12.1-2-3 (d).

This **ORDER** is effective upon issuance.

If you wish to request a hearing on this **ORDER**, pursuant to IC 4-21-.5-4, you are required to forward a written request to the Indiana State Department of Health, at the office of Secretary, 2 North Meridian Street, Indianapolis, Indiana 46204 on or before **June 17, 2011**.

Dated at Indianapolis, Indiana this 13th day of May 2011.

Respectfully submitted,

DIVISION OF WEIGHTS AND MEASURES,
MOTOR FUEL INSPECTION PROGRAM OF THE
INDIANA STATE DEPARTMENT OF HEALTH

Larry J. Stump, Director
Division of Weights and Measures,
Motor Fuel Inspection
lstump@isdh.in.gov
317-356-7078 ext.225

Received by: _____

Date: May 13, 2011